



NOTE:
MOTOR #2 ONLY
PROVIDED ON
SIZES 08, 10 & 12

Optional
PULL JP1 FOR UNIT MOUNTED REMOTE
TEMP SENSOR

LEGEND

- FIELD WIRED
- FACTORY WIRED
- FIELD CONNECTION
- FACT. CONNECTION
- + FACTORY WIRE - NOT CONNECTED
- WIRE TERMINATION

- NOTES:**
- COMPLETE THE WIRING IN ACCORDANCE WITH NATIONAL AND LOCAL CODES.
 - USE SOLID COPPER SUPPLY WIRES.
 - CONNECTOR LABEL MATCHES SUB-PANEL.
 - ONLY USE DIRECT REPLACEMENT COMPONENTS.
 - FIELD INSTALLED REMOTE TEMPERATURE SENSOR: WIRE TO THERMOSTAT TB1 TERMINALS 1 AND 2.
 - CONTROLLER SHIPPED LOOSE IF WALL MOUNTED.
 - CONTROL VALVE IS SHIPPED LOOSE.

CAUTION: NOT FOLLOWING
PROPER WIRING PROCEDURE
CAN CAUSE INJURY OR DEATH.

	NAME	DATE
DRAWN BY	MDO	08/07/2024
MECH APPR.	--	--
ELEC APPR.	--	--
ENG APPR.	--	--
MFG APPR.	--	--

zehnder Buffalo, New York
Rittling

DESCRIPTION
2F4T PSC 3SPD 120/60/1
UMC TEMP CUH DRAWING

SIZE	PART NO.	REV.
B	11D00035927A	A

SHEET 1 OF 1

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS
DRAWING IS THE SOLE PROPERTY OF
ZEHNDER. ANY REPRODUCTION IN PART
OR AS A WHOLE WITHOUT THE WRITTEN
PERMISSION OF ZEHNDER IS PROHIBITED.