



NOTE:
MOTOR #2 ONLY
PROVIDED ON
SIZES 08, 10 & 12

Optional
PULL JP1 FOR UNIT MOUNTED REMOTE
TEMP SENSOR

LEGEND

- FIELD WIRED
- FACTORY WIRED
- FIELD CONNECTION
- FACT. CONNECTION
- + FACTORY WIRE – NOT CONNECTED
- WIRE TERMINATION

- NOTES:**
- COMPLETE THE WIRING IN ACCORDANCE WITH NATIONAL AND LOCAL CODES.
 - USE SOLID COPPER SUPPLY WIRES.
 - CONNECTOR LABEL MATCHES SUB-PANEL.
 - ONLY USE DIRECT REPLACEMENT COMPONENTS.
 - FIELD INSTALLED REMOTE TEMPERATURE SENSOR: WIRE TO THERMOSTAT TB1 TERMINALS 1 AND 2.
 - CONTROLLER SHIPPED LOOSE IF WALL MOUNTED.
 - CONTROL VALVE IS SHIPPED LOOSE.

	NAME	DATE
DRAWN BY	DH	10/29/24
MECH APPR.	--	--
ELEC APPR.	--	--
ENG APPR.	--	--
MFG APPR.	--	--

zehnder Buffalo, New York
Rittling

DESCRIPTION
2V0T PSC 3SPD 120/60/1
UMC TEMP CUH DRAWING

SIZE	PART NO.	REV.
B	11D00035929A	A

SHEET 1 OF 1

CAUTION: NOT FOLLOWING
PROPER WIRING PROCEDURE
CAN CAUSE INJURY OR DEATH.

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS
DRAWING IS THE SOLE PROPERTY OF
ZEHNDER. ANY REPRODUCTION IN PART
OR AS A WHOLE WITHOUT THE WRITTEN
PERMISSION OF ZEHNDER IS PROHIBITED.